

KE3 - Delta VFD- Type E

MI1 Forward = 62

MI2 Reverse = 61


DCM Common= 2

ACM Common control signal = 7

AVI Analog voltage input = 6

+10V Potentiometer power supply = 5

AFM Analog output meter = 12



Parameter setting

01-00 Max output Freq =207 Hz

01-01 Max vol Freq = 60 Hz

01-02 Max output volt = 220 V

01-09 Accel time = 1.5 seconds

01-10 Decel Time = 1.5 seconds

02-00 1st Freq source = 1

02-01 Command source = 1

02-02 Stop method = 0

03-03 AFM selection = 0

V2I 3HP INV USA

